

2023 Consumer Confidence Report (CCR) Certification Form

Water System Name: Town of Cameron

Water System No.: NC 03-63-040 Report Year: 2023 Population Served: 326

The Community Water System (CWS) named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory. In addition, if this report is being used to meet Tier 3 Public Notification requirements, as denoted by the checked box below, the CWS certifies that public notification has been provided to its consumers in accordance with the requirements of 40 CFR 141.204(d).

Certified by: Name: Brandon Brown

Title: Distribution ORC

Signature: 

Phone #: 910-245-3212

Delivery Achieved Date: _____

Date Reported to State: _____

The CCR includes the mandated Tier 3 Public Notice for a monitoring/reporting violation (check box, if yes).

Check all methods used for distribution (see instructions on back for delivery requirements and methods):

☐ Paper copy to all ☐ US Mail ☐ Hand Delivery

☐ Notification of availability of paper copy (Provide a copy of the notice.)

Notification Method _____ (i.e., US Mail, door hanger)

X Notification of CCR URL (must be direct URL): Notification of CCR URL (must be direct URL):

<http://www.townofcameron.com/government/reports>

Notification Method _____ (i.e., on bill, bill stuffer, separate mailing, email)

☐ Direct email delivery of CCR ☐ Attached ☐ Embedded

Notification Method _____ (i.e., on bill, bill stuffer, separate mailing)

☐ Newspaper (attach copy) Name of Paper? _____ Date Published: _____

Notification Method _____ (i.e., on bill, bill stuffer, separate mailing, email)

☐ "Good faith" efforts (in addition to one of the above required methods) were used to reach non-bill paying consumers such as industry employees, apartment tenants, etc. Extra efforts included the following methods:

- ☐ posting the CCR on the Internet at URL: _____
- ☐ mailing the CCR to postal patrons within the service area
- ☐ advertising the availability of the CCR in news media (attach copy of announcement)
- ☐ publication of the CCR in local newspaper (attach copy of newspaper)
- ☐ posting the CCR in public places such as: (attach list if needed) _____
- ☐ delivering multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers
- ☐ delivery to community organizations such as: (attach list if needed) _____

Note: Use of social media (e.g., Twitter or Facebook) or automated phone calls DO NOT meet existing CCR

INSTRUCTIONS for Water System (Remove this page prior to distribution.)

- Create your 2023 CCR using the template and instructions on the following pages
 - Make sure all instructions are removed when report is complete. Instructions are in blue text with ** symbols at the beginning of each paragraph. The **s are included in case the blue color is not visible.**
 - Systems that have a large proportion of non-English speaking customers must include information in the appropriate language(s) regarding the importance of the report or provide a telephone number or address where such residents may contact the system to obtain a translated copy of the report or assistance in the appropriate language.
 - It is best to remove all non-detected contaminants and all contaminants not required to be monitored by the water system from the report. This will make the report shorter, so that it is easier to read and less expensive to print. If you wish to include non-detected contaminants in your report, the CCR Rule requires that all detected and non-detected contaminants be presented in separate tables.
 - A detected contaminant stays in the report from year to year until the particular contaminant is tested again, in which case, the result may either be modified, if detected again, or removed, if not detected. No data older than 5 years needs to be included.
- Distribute your 2023 CCR to customers through direct delivery

CCR DELIVERY METHOD	METHOD DESCRIPTION (Click link: EPA-CCR Rule Delivery Options Memo January 3, 2013 , for referenced Appendix Figures below.)
Mail – paper copy	CWS mails a paper copy of the CCR to each bill-paying customer.
Mail – notification that CCR is available on web site via a direct URL	CWS mails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the “directly deliver” requirement. The mail method for the notification may be, but is not limited to, a water bill insert, statement on the water bill or community newsletter. See Figure 1 in the Appendix. A copy of the notice of the direct URL must be submitted to the State with the CCR and Certification Form.
Email – direct URL to CCR	CWS emails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the “directly deliver” requirement. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 2 in the Appendix. A copy of the email must be submitted to the State with the CCR and Certification Form.
Email – CCR sent as an attachment to email	CWS emails the CCR as an electronic file email attachment [e.g., portable document format (PDF)]. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 3 in the Appendix. A copy of the email must be submitted to the State with the CCR and Certification Form.
Email – CCR sent as an embedded image in an email	CWS emails the CCR text and tables inserted into the body of an email (not as an attachment.) This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 4 in the Appendix. A copy of the email must be submitted to the State with the CCR and Certification Form.
Additional electronic delivery that meets “otherwise directly deliver” requirement	CWS delivers CCR through a method that “otherwise directly delivers” to each bill-paying customer and in coordination with the primacy agency. This category is intended to encompass methods or technologies not included above. CWSs and primacy agencies considering new methods or technologies should consult with the EPA to ensure it meets the intent of “otherwise directly deliver.”

➤ **Systems serving 100,000 or more persons must** post the CCR on a publicly accessible Internet site using a direct URL.

➤ **Systems serving 10,000 or more persons must** distribute the CCR using a delivery method in the table above.

➤ **Systems serving less than 10,000 persons but more than 500 persons must either:** (1) distribute the CCR using a delivery method in the table above **OR** (2) notify their customers that the CCR is not being mailed, but it will be in what newspaper(s) and when (attach copy of notice). The complete CCR should be printed in the local newspaper, and a copy of the CCR must be made available upon request. *(The*

2nd option is not acceptable if using the CCR for Tier 3 Public Notification!)

➤ **Systems serving 500 or fewer persons must either:** (1) distribute the CCR using a delivery method in the table above **OR** (2) notify their customers that the CCR is not being mailed, and a copy of the CCR must be made available upon request. *(The 2nd option is not*

acceptable if using the CCR for Tier 3 Public Notification!) A copy of the notice must be submitted to the State with the CCR and Certification Form.

Note: Use of social media or automated phone calls DO NOT meet existing CCR distribution methods under the Rule.

- Submit and certify a copy of the CCR and all supporting documentation (copy of notice, email, or bill example) through our ECERT Online Certification application in one PDF file

ECERT Online Certification and Submittal of CCR: <https://pws.ncwater.org/ECERT/pages/default.aspx>

The certification form on the previous page is not required for CCRs submitted through ECERT. For assistance with accessing ECERT please email PWSS.CCR@ncdenr.gov or go to

<https://pws.ncwater.org/ECERT/pages/CCRHELP.pdf>

If you do not have access to the internet, you can mail your CCR, Certification form, and supporting documentation to: *Public Water Supply Section, 1634 Mail Service Center, Raleigh, NC 27699-1634, Attn: CCR Rule Manager* or FAX your CCR, Certification form, and supporting documentation to (919) 715-6637, Attn: *CCR Rule Manager*

2023 Annual Drinking Water Quality Report ***“Town Of Cameron”***

Water System Number: “03-63-040”

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Town Hall at 910-245-3212. We want our valued customers to be informed about their water utility.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Name of Utility] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is (ground water) and is located at Hwy 24 27 (Cameron) and on Dalrymple Rd (Cameron)

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Town of Cameron was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)		
Source Name	Susceptibility Rating	SWAP Report Date
Well # 7	Lower	September 2021
Well #8	Lower	September 2021

The complete SWAP Assessment report for Town of Cameron may be viewed on the Web at: <https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. We have implemented the following source water protection actions: (Well Head Protection Plan) You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

Violations that Your Water System Received for the Report Year

During 2023, or during any compliance period that ended in 2023, we received one violation which was due to Nitrate not being sampled in 2023.

Important Drinking Water Definitions:

- *Not-Applicable (N/A)* – Information not applicable/not required for that particular water system or for that particular rule.
- *Non-Detects (ND)* - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
- *Parts per million (ppm) or Milligrams per liter (mg/L)* - One part per million corresponds to one minute in two years or a single penny in \$10,000.
- *Parts per billion (ppb) or Micrograms per liter (ug/L)* - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- *Parts per trillion (ppt) or Nanograms per liter (nanograms/L)* - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- *Parts per quadrillion (ppq) or Picograms per liter (picograms/L)* - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

- **Picocuries per liter (pCi/L)** - Picocuries per liter is a measure of the radioactivity in water.
- **Million Fibers per Liter (MFL)** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- **Nephelometric Turbidity Unit (NTU)** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **Variances and Exceptions** – State or EPA permission not to meet an MCL or Treatment Technique under certain conditions.
- **Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.
- **Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Locational Running Annual Average (LRAA)** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Running Annual Average (RAA)** – The average of sample analytical results for samples taken during the previous four calendar quarters.
- **Level 1 Assessment** - *A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.*
- **Level 2 Assessment** - *A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.*
 - **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
 - **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2023.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Inorganic Contaminants

Well 8

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Antimony (ppb)	11/22	N	<			6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	11/22	N	<			0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	11/22	N	<			2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	11/22	N	<			4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	11/22	N	<			5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	11/22	N	<			100	100	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppb)	11/22	N	<			200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm)	11/22	N	.1460			4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic) (ppb)	11/22	N	<			2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppb)	11/22	N	<			50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium (ppb)	11/22	N	<			0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Well 7

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Antimony (ppb)	11/22	N	<			6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	11/22	N	<			0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	11/22	N	<			2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	11/22	N	<			4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	11/22	N	<			5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	11/22	N	<			100	100	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppb)	11/22	N	<			200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm)	11/22	N	.1050			4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic) (ppb)	11/22	N	<			2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppb)	11/22	N	<			50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium (ppb)	11/22	N	<			0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Arsenic: While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Nitrate/Nitrite Contaminants

Well 8

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm)	10/08/23	N	<	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	10/08/23	N	<	N/A		1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Well 7

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm)	10/08/23	N	<	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	10/08/23	N	<	N/A		1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)						7	7	Decay of asbestos cement water mains; erosion of natural deposits

Synthetic Organic Chemical (SOC) Contaminants Including Pesticides and Herbicides

Well 8

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
2,4-D (ppb)	11/22	N	<			70	70	Runoff from herbicide used on row crops
2,4,5-TP (Silvex) (ppb)	11/22	N	<			50	50	Residue of banned herbicide
Alachlor (ppb)	11/22	N	<			0	2	Runoff from herbicide used on row crops
Atrazine (ppb)	11/22	N	<			3	3	Runoff from herbicide used on row crops
Benzo(a)pyrene (PAH) (ppt)	11/22	N	<			0	200	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	11/22	N	<			40	40	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	11/22	N	<			0	2	Residue of banned termiticide
Dalapon (ppb)	11/22	N	<			200	200	Runoff from herbicide used on rights of way
Di(2-ethylhexyl) adipate (ppb)	11/22	N	<			400	400	Discharge from chemical factories

Di(2-ethylhexyl) phthalate (ppb)	11/22	N	<		0	6	Discharge from rubber and chemical factories
DBCP [Dibromochloropropane] (ppt)	11/22	N	<		0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	11/22	N	<		7	7	Runoff from herbicide used on soybeans and vegetables
Endrin (ppb)	11/22	N	<		2	2	Residue of banned insecticide
EDB [Ethylene dibromide] (ppt)	11/22	N	<		0	50	Discharge from petroleum refineries
Heptachlor (ppt)	11/22	N	<		0	400	Residue of banned pesticide
Heptachlor epoxide (ppt)	11/22	N	<		0	200	Breakdown of heptachlor
Hexachlorobenzene (ppb)	11/22	N	<		0	1	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	11/22	N	<		50	50	Discharge from chemical factories
Lindane (ppt)	11/22	N	<		200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	11/22	N	<		40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate] (ppb)	11/22	N	<		200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	11/22	N	<		0	500	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	11/22	N	<		0	1	Discharge from wood preserving factories
Picloram (ppb)	11/22	N	<		500	500	Herbicide runoff
Simazine (ppb)	11/22	N	<		4	4	Herbicide runoff
Toxaphene (ppb)	11/22	N	<		0	3	Runoff/leaching from insecticide used on cotton and cattle

Well 7

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
2,4-D (ppb)	11/22	N	<			70	70	Runoff from herbicide used on row crops
2,4,5-TP (Silvex) (ppb)	11/22	N	<			50	50	Residue of banned herbicide
Alachlor (ppb)	11/22	N	<			0	2	Runoff from herbicide used on row crops
Atrazine (ppb)	11/22	N	<			3	3	Runoff from herbicide used on row crops
Benzo(a)pyrene (PAH) (ppt)	11/22	N	<			0	200	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	11/22	N	<			40	40	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	11/22	N	<			0	2	Residue of banned termiticide
Dalapon (ppb)	11/22	N	<			200	200	Runoff from herbicide used on rights of way
Di(2-ethylhexyl) adipate (ppb)	11/22	N	<			400	400	Discharge from chemical factories
Di(2-ethylhexyl) phthalate (ppb)	11/22	N	<			0	6	Discharge from rubber and chemical factories
DBCP [Dibromochloropropane] (ppt)	11/22	N	<			0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	11/22	N	<			7	7	Runoff from herbicide used on soybeans and vegetables
Endrin (ppb)	11/22	N	<			2	2	Residue of banned insecticide
EDB [Ethylene dibromide] (ppt)	11/22	N	<			0	50	Discharge from petroleum refineries

Heptachlor (ppt)	11/22	N	<		0	400	Residue of banned pesticide
Heptachlor epoxide (ppt)	11/22	N	<		0	200	Breakdown of heptachlor
Hexachlorobenzene (ppb)	11/22	N	<		0	1	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	11/22	N	<		50	50	Discharge from chemical factories
Lindane (ppt)	11/22	N	<		200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	11/22	N	<		40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate] (ppb)	11/22	N	<		200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	11/22	N	<		0	500	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	11/22	N	<		0	1	Discharge from wood preserving factories
Picloram (ppb)	11/22	N	<		500	500	Herbicide runoff
Simazine (ppb)	11/22	N	<		4	4	Herbicide runoff
Toxaphene (ppb)	11/22	N	<		0	3	Runoff/leaching from insecticide used on cotton and cattle

Volatile Organic Chemical (VOC) Contaminants

Well 8

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Benzene (ppb)	11/22	N	<			0	5	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	11/22	N	<			0	5	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	11/22	N	<			100	100	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	11/22	N	<			600	600	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	11/22	N	<			75	75	Discharge from industrial chemical factories
1,2 – Dichloroethane (ppb)	11/22	N	<			0	5	Discharge from industrial chemical factories
1,1 – Dichloroethylene (ppb)	11/22	N	<			7	7	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	11/22	N	<			70	70	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	11/22	N	<			100	100	Discharge from industrial chemical factories
Dichloromethane (ppb)	11/22	N	<			0	5	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	11/22	N	<			0	5	Discharge from industrial chemical factories
Ethylbenzene (ppb)	11/22	N	<			700	700	Discharge from petroleum refineries
Styrene (ppb)	11/22	N	<			100	100	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	11/22	N	<			0	5	Discharge from factories and dry cleaners
1,2,4 –Trichlorobenzene (ppb)	11/22	N	<			70	70	Discharge from textile-finishing factories
1,1,1 – Trichloroethane (ppb)	11/22	N	<			200	200	Discharge from metal degreasing sites and other factories
1,1,2 –Trichloroethane (ppb)	11/22	N	<			3	5	Discharge from industrial chemical factories
Trichloroethylene (ppb)	11/22	N	<			0	5	Discharge from metal degreasing sites and other factories
Toluene (ppm)	11/22	N	<			1	1	Discharge from petroleum factories
Vinyl Chloride (ppb)	11/22	N	<			0	2	Leaching from PVC piping; discharge from plastics factories
Xylenes (Total) (ppm)	11/22	N	<			10	10	Discharge from petroleum factories; discharge from chemical factories

Well 7

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Benzene (ppb)	11/22	N	<			0	5	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	11/22	N	<			0	5	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	11/22	N	<			100	100	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	11/22	N	<			600	600	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	11/22	N	<			75	75	Discharge from industrial chemical factories
1,2 – Dichloroethane (ppb)	11/22	N	<			0	5	Discharge from industrial chemical factories
1,1 – Dichloroethylene (ppb)	11/22	N	<			7	7	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	11/22	N	<			70	70	Discharge from industrial chemical factories

trans-1,2-Dichloroethylene (ppb)	11/22	N	<		100	100	Discharge from industrial chemical factories
Dichloromethane (ppb)	11/22	N	<		0	5	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	11/22	N	<		0	5	Discharge from industrial chemical factories
Ethylbenzene (ppb)	11/22	N	<		700	700	Discharge from petroleum refineries
Styrene (ppb)	11/22	N	<		100	100	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	11/22	N	<		0	5	Discharge from factories and dry cleaners
1,2,4 -Trichlorobenzene (ppb)	11/22	N	<		70	70	Discharge from textile-finishing factories
1,1,1 - Trichloroethane (ppb)	11/22	N	<		200	200	Discharge from metal degreasing sites and other factories
1,1,2 -Trichloroethane (ppb)	11/22	N	<		3	5	Discharge from industrial chemical factories
Trichloroethylene (ppb)	11/22	N	<		0	5	Discharge from metal degreasing sites and other factories
Toluene (ppm)	11/22	N	<		1	1	Discharge from petroleum factories
Vinyl Chloride (ppb)	11/22	N	<		0	2	Leaching from PVC piping; discharge from plastics factories
Xylenes (Total) (ppm)	11/22	N	<		10	10	Discharge from petroleum factories; discharge from chemical factories

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water (90 th Percentile)	Number of sites found above the AL		MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	10/21	.179	0		1.3	AL=1.3	Corrosion of household plumbing system; erosion of natural deposits
Lead (ppb) (90 th percentile)	10/21	0	0		0	AL=15	Corrosion of household plumbing system; erosion of natural deposits

Radiological Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water (RAA)	Range Low High	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L) (Gross Alpha Excluding Radon and Uranium)	12/19	N	N/D		0	15	Erosion of natural deposits
Beta/photon emitters (pCi/L)	12/19	N	N/D		0	50 *	Decay of natural and man-made deposits
Combined radium (pCi/L)	N/A	N/A	N/A		0	5	Erosion of natural deposits
Uranium (pCi/L)	12/19	N	N/D		0	20.1	Erosion of natural deposits

* Note: The MCL for beta/photon emitters is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

Total Organic Carbon (TOC)

Contaminant (units)	TT Violation Y/N	Your Water (lowest RAA)	Range Monthly Removal Ratio Low - High	MCLG	Treatment Technique (TT) violation if:	Likely Source of Contamination
Total Organic Carbon (TOC) Removal Ratio (no units)				N/A	Removal Ratio RAA <1.00 and alternative compliance criteria was not met	Naturally present in the environment

Disinfectant Residuals Summary

01/2023

	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
			Low	High			
Chlorine (ppm)	N	0.95	.76	1.16	4	4.0	Water additive used to control microbes
Chloramines (ppm)					4	4.0	Water additive used to control microbes
Chlorine dioxide (ppb)		N/A			800	800	Water additive used to control microbes

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)	11/22	N				N/A	80	Byproduct of drinking water disinfection
Location (Ex. B01)								
HAA5 (ppb)						N/A	60	Byproduct of drinking water disinfection
Location (Ex. B01)								

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Other Disinfection Byproducts Contaminants

Contaminant (units)	MCL/MRDL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
			Low	High			
Bromate (ppb)					0	10	By-product of drinking water disinfection
Chlorite (ppm)					0.8	1.0	By-product of drinking water chlorination

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Other Miscellaneous Water Characteristics Contaminants

Well8

Contaminant (units)	Sample Date	Your Water	Range		SMCL
			Low	High	
Iron (ppm)	11/22	.088			0.3 mg/L
Manganese (ppm)	11/22	.02			0.05 mg/L

Nickel (ppm)				N/A
Sodium (ppm)	11/22	8.75		N/A
Sulfate (ppm)				250 mg/L
pH	11/22	7.95		6.5 to 8.5

Well 7

Contaminant (units)	Sample Date	Your Water	Range Low High	SMCL
Iron (ppm)				0.3 mg/L
Manganese (ppm)				0.05 mg/L
Nickel (ppm)				N/A
Sodium (ppm)	11/22	13.80		N/A
Sulfate (ppm)				250 mg/L
pH	11/22	7.71		6.5 to 8.5